


Thermostat User Guide

Cuarto - Tahoe Hall

Tahoe Hall is equipped with Siemens Controls thermostats. These thermostats control the temperature in the room based on pre-set limits. Residents can select comfortable heating/cooling temperatures within 3.5 degrees (on either side) of the standard set point by selecting the “+” and “-” to adjust the temperature in the room. When the “+” and “-” buttons are pressed a bar should fill the screen. If you continue to press the “-” sign, the bar will “empty” by shifting to the left. If you press the “+” sign, the bar will “fill” by shifting to the right.



Troubleshooting:

Room is Too Hot

1. Press the “-” button – is the bar “empty”?
If not, Press the “-” button until the filled in area on the bar disappears or until the desired temperature is reached.
2. Are the windows open?
 - a. If outside temperatures are warmer than inside temperatures, close all windows to allow maximum efficiency.
 - b. If outside temperatures are cooler than inside temperatures, open windows to allow increased cooling.

Room is Too Cold

1. Press the “+” button – is the bar “full”?
If not, If not, Press the “+” button until the filled in area fills the entire bar or until the desired temperature is reached.
2. Are the windows open?
 - a. If outside temperatures are cooler than inside temperatures, close all windows to allow maximum efficiency.
 - b. If outside temperatures are warmer than inside temperatures, open windows to allow increased warming.

If the above actions do not resolve the problem, please submit a service request on-line (Academic Year Residents and/or Staff). Contact your respective Area Service Desk if immediate response is required.